



Winter Home Maintenance Checklist


DECEMBER

- Monitor indoor humidity levels and adjust humidifier as required.
- Check furnace filter and replace if necessary.
- Ensure exterior vents (HRV, dryer, bathroom) are clear of snow and ice.
- Inspect attic access hatch for proper sealing.
- Test smoke alarms and carbon monoxide detectors; replace batteries if required.
- Check water heater for leaks.

JANUARY

- Inspect furnace filter and replace if required.
- Check range hood and bathroom exhaust fans for proper operation.
- Inspect visible plumbing lines for signs of freezing or condensation.
- Ensure sump pump is operational if applicable.
- Test smoke alarms and carbon monoxide detectors; replace batteries if required.

FEBRUARY

- Inspect furnace filter and replace if necessary.
 - Check HRV filters and clean if required.
 - Clear lint from clothes dryer exterior vent.
 - Inspect windows and doors for condensation or frost buildup.
 - Test smoke alarms and carbon monoxide detectors; replace batteries if required.
- 
- A large, semi-circular decorative graphic in the bottom right corner of the page. It features a stylized house or building shape composed of various shades of green and yellow, set against a light gray background. The graphic is partially cut off by the right edge of the page.